

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**FAN COIL UNIT/ DUCTLESS MINI SPLIT**

SITE AND BLDG #: WVO91-01

LOCATION/RM #: CMs WO# 10953

ASSET # 5295

MECHANIC  
SIGNATURE: 

DATE: 9/2/13

START TIME: 8:45

FINISH TIME: 9:00

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary.
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 3 Tighten all electrical connectors to proper torque as needed.
- 4 Check that the fan runs properly in all speeds as applicable.
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.
- 7 Lubricate mechanical connections of dampers sparingly as applicable.
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 10 Check coils for leaking, tightness of fittings.
- 11 Use fin comb to straighten coil fins as needed.

N/A  
N/A

/

N/A

/

/

/

N/A

/

/

N/A

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

N/A

/

N/A

/

N/A

/

/

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker  
 Additional Notes:

2 R