

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: WV 043 -02

LOCATION/RM #: OMS

WO# 10874

ASSET # 0081

MECHANIC
SIGNATURE: 

DATE: 9/24/19

START TIME: 1028

FINISH TIME: 1030

ITEM NO.	DESCRIPTION	TESTS PERFORMED		NOTES/DEFICIENCIES
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
3	Start and stop fan with local switch		/	
4	Check motor and fan shaft bearings for noise, vibration, overheating, lubricate bearings.	/		
5	Inspect, adjust belts and pulleys. Replace belt as needed.	/		
6	Clean dampers, lubricate pivot points (annually) and inspect linkages for tightness.	/		
7	Inspect fan for bent blades, unbalance, excessive noise and vibration.	/		
8	Clean fan as needed.	/		
9	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	/		
10	Repair as needed.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

BC