

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

VAULT DOOR

SITE AND BLDG #: WV046-01

LOCATION/RM #:

MECHANIC
SIGNATURE: *Mike Merchant* **DATE:** *24 Jul 19*

START TIME: *8:30 AM* **FINISH TIME:** *10:00 AM*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV046-01	9776	7914					J-1502000-55 1-pc Arms Vault, Armor Vault Anti-Room	
WV046-01	9776	7917					J-1502000-55 1-pc Arms Vault, Off of Assembly Hall	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO			
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		<i>Completed by Sub.</i>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		<i>See COA.</i>		
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Check alignment of dial ring with lock case; correct if necessary.	<input checked="" type="checkbox"/>				
2	Check mounting screws of dial ring and lock case; tighten them, using a thread locking compound.	<input checked="" type="checkbox"/>				
3	Look for corrosion or presence of any foreign matter that will in any manner affect the lock's proper operation.	<input checked="" type="checkbox"/>				
4	Look for any signs of malfunctioning or impending failure.	<input checked="" type="checkbox"/>				
5	Look for any signs of tampering, forced, or covert entry; report this to the local Security and Law Enforcement Office.	<input checked="" type="checkbox"/>				

6	Check Alignment of door with frame	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Check for difficulty in opening, closing or locking the door.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Replace all defective hardware	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker

Additional Notes: