

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**GATES, FENCES, SECURITY AND ACCESS**

**SITE AND BLDG #:** WV046-01

**MECHANIC  
SIGNATURE:** *John E. G-*

**DATE:** 29JUL19

**LOCATION/RM #:** EXTERIOR

**START TIME:** 9:00A

**FINISH TIME:** 10:00P

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV046-01	9852	7555					J-1502000-49 Manual Gate	
WV046-01	9901	7508					J-1502000-49 1-pc Double Gate, Manual Sliding Entrance between USARC and MotorPool	
WV046-01	9901	7509					J-1502000-49 1-pc Double Gate, Manual Sliding Entrance to South Motor Pool from OMS	
WV046-01	9901	7510					J-1502000-49 1-pc Double Gate, Manual Sliding Entrance to the North Motor Pool from OMS	
WV046-01	9901	7511					J-1502000-49 1-pc Double Gate, Manual Sliding Entrance to Driveway	
WV046-01	9901	7650					J-1502000-49 1-pc Single Gate Manual Swinging Walking Gate between Parking Area And OMS	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	NO ELECTRIC GATES
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
<b>GATES</b>				
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	✓		
2	Check all locking devices. Lubricate as required.	✓		

*Bjh*

3	Inspect center gate support rollers and lubricate as required.	<input checked="" type="checkbox"/>		
4	Clean roller track of any debris.	<input checked="" type="checkbox"/>		
5	Check bolts, fasteners, and mounting hardware. Tighten or adjust as necessary.	<input checked="" type="checkbox"/>		
6	Check for any obstructions that retard full swing or movement of the gate.	<input checked="" type="checkbox"/>		
7	Check that shrubs and trees are pruned clear of gate.	<input checked="" type="checkbox"/>		
8	Check hold open devices for proper operation. Lubricate as required.		<input checked="" type="checkbox"/>	N/A

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>FENCES</b>				
1	Check posts and corner posts, support guys, and horizontal bars between each support post.	<input checked="" type="checkbox"/>		
2	Check wire and anchor point; re-stretch and re-anchor if necessary.	<input checked="" type="checkbox"/>		
3	Inspect fence anchors along the bottom of the fence and at the point where the fence is connected to the post.	<input checked="" type="checkbox"/>		
4	Treat with galvanized protectant where rust has developed.		<input checked="" type="checkbox"/>	N/A
5	If approved, apply weed control along entire base of fence. Consult the Safety Data Sheets (SDS) for hazardous ingredients and proper personal protective equipment (PPE).		<input checked="" type="checkbox"/>	NOT APPROVED
6	Check that shrubs and trees are pruned clear of fencing	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**



