

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**MANUAL/AUTOMATIC OVERHEAD DOORS**

**SITE AND BLDG #:** WV046-01

**MECHANIC**  
**SIGNATURE:**

**DATE:** 19

**LOCATION/RM #:**

**START TIME:**

**FINISH TIME:**

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV046-01	9901	8021					J-1502000-56 1-pc Small Interior Roll-up Fire Door, 3Wx3H	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>					
1	Check with door operating personnel for any known deficiencies.	✓			
2	Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.	✓	✓	N/A	
3	If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed.		✓	NON POWERED	
4	Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.		✓	N/A	



5	Check manual operation. Note brake release, motor disengagement, functioning or hand pulls, chains sprockets, clutch, etc.	<input checked="" type="checkbox"/>		
6	If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.		<input checked="" type="checkbox"/>	N/A
7	If applicable, inspect gear box, change or add oil as required.		<input checked="" type="checkbox"/>	N/A
8	Perform required lubrication. Remove old or excess lubricant.	<input checked="" type="checkbox"/>		
9	Clean unit and mechanism thoroughly. Touch up paint where required.	<input checked="" type="checkbox"/>		
10	Clean up and remove all debris.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

