

REVIEWED

By Mike Merchan at 1:40 pm, Feb 26, 2019

TIDEWATER-ELEC-SLP-01

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
PHOTOCELL CONTACTS

ACTIVITY AND BLDG #: WV046-02

MECHANIC

SIGNATURE:

Patrick Davis

DATE: 25 February 2019

LOCATION: LOTSTART TIME: 1:30FINISH TIME: 2:30

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV046-02	7327	7455		<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	J-1502000-45 4-pc 2 LED Fixture Steel LED Photocell Contacts	<u>LOT</u>

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Review manufacturer's instructions.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean solar panels thoroughly to ensure surface is free of dirt, dust, bug residue, etc.	✓		
2	Inspect panels to determine if any panels exhibit cracks, breaks, or defects that would be cause for concern, repair or replace as needed.	✓		
3	Inspect wiring for damage, fraying, discoloration, etc. Repaire or replace as needed.	✓		
4	Ensure controller is operating properly and free from damage. Report any deficiencies	✓		

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence.

Checklist compiled in accordance with:

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at ([Provide Link to OEM Manual/Asset Library](#))

Additional Notes:

Page 1 of 1

