

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**GLYCOL TANK**

SITE AND BLDG #: WV046-01

MECHANIC  
SIGNATURE:

DATE: 12/5/24

LOCATION/RM #:

WO# 17274

ASSET # 9326

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		Glycol Feeder
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Examine exterior of tank, including fittings, gauges, structural supports, manholes, and handholes for leaks, signs of corrosion, or other defects.	●		
2	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.		●	Controls appear to be out of service.
3	Check condition of agitators and/or float assemblies.	●		
4	If applicable, clean strainer(s).	●		
5	Clean up work site.- Report any issues	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

