

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OIL WATER SEPARATOR

SITE AND BLDG #: **WV046-01**

MECHANIC
SIGNATURE: James R Groft Jr

DATE: **09/30/2025**

LOCATION/RM #:

WO# 20052**ASSET # 9330**

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		Visual Inspection Only, Approved contractor performs PM checklist procedures at recommended intervals to satisfy contractual requirements
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	OIL LAYER - If possible, measure the surface oil layer in the oil water separator and record depth.		X	  
2	SOLID ACCUMULATION - If possible, measure the solid accumulation in the bottom of the oil water separator and record.		X	  
3	Recommend whether oil water separator needs to be cleaned.	X		  

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: