

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST OUTDOOR CONDENSING UNIT

SITE AND BLDG #: WV046-01

MECHANIC


SIGNATURE: James R Groft JrDATE: 11/30/2025

LOCATION/RM #:

WO#20458ASSET #3244

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule outage of unit with personnel in area the unit serves.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		Unit had minor hail damage which was corrected
3	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Remove debris from air screen and clean underneath unit.	X		
2	Wash coil with coil cleaning solution - Rinse Thoroughly	X		
3	Straighten fin tubes with fin comb, as needed.	X		
4	Check electrical connections for tightness.	X		
5	Check mounting base for tightness.	X		
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	X		
7	Inspect all piping for leaks and tighten loose connections.	X		
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	X		
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.and Humidity		X	N/A Room temp _____ Room Humidity _____%
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		
11	Clean up work area.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**