PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: WV046-01

MECHANIC SIGNATURE: James R Groft **DATE:** 02/27/2026

LOCATION/RM #: **WO#** 20983 Asset 3054 3055

START TIME: **FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES	TASK COMPLETE NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
	TO BE PERFORMED AT EACH INSPECTION SERVICE			
1	Check, clean, and/or replace filters as required.	X		
2	Initial and Date Filter (if disposable)	X		
3	Initial and Date Yellow Maintenance Tag (if applicable)	X		

ASSET #	SIZE	QTY	NOTES/ ACTIONS
	Record Size : 16 x 25 x 2	8	
	20 x 25 x 2	8	
	 		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly		
	All other filters get replaced annually But inspected Quarterly		

Note: The technician shall perform any repairs identified during PM up to $250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding $250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Technician
Additional Notes: