

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FIRE EXTINGUISHERS - MONTHLY INSPECTION

SITE AND BLDG #: WV046-02











MECHANIC
SIGNATURE:

DATE: Apr 29, 2024

LOCATION/RM #: WO# 15317 ASSET # G074

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES <input type="checkbox"/> NO <input type="checkbox"/>	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)					
			SPECIAL INSTRUCTIONS					
1	Each extinguisher shall have an inspection tag securely attached that indicates the month and year the inspection was performed and the initials of the person performing the inspection shall be recorded.	<input checked="" type="checkbox"/>						
	TO BE PERFORMED AT EACH INSP							
1	A visual inspection is a quick check to see that the fire extinguisher is in its proper location, that it is not blocked, is fully charged, and that it appears to be in good working order.	<input checked="" type="checkbox"/>						
2	Check that extinguisher is in designated place	<input checked="" type="checkbox"/>						
3	Check for no obstruction to access or visibility.	<input checked="" type="checkbox"/>						
4	Check that pressure gauge reading or indicator is in the operable range or position.	<input checked="" type="checkbox"/>						
5	Update tag indicating that inspection has been performed. Include the date and your initials.	<input checked="" type="checkbox"/>						

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor, parts, and materials). If the repair cost exceeds \$250, open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the defect.

To be performed by: General Maintenance Worker

Additional Notes: