

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

CHEMICAL BYPASS/POT FEEDER

SITE AND BLDG #: [WV046-02](#)

MECHANIC

SIGNATURE: [James R Groft Jr](#)DATE: [09/30/2025](#)LOCATION/RM #: WO# [19973](#) ASSET # [9336](#)

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO		
SPECIAL INSTRUCTIONS					
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check physical condition of feeder. Clean and/or repair as needed.	X			
2	Check valves for proper operation. Ensure no leaks are present and repair as needed.	X			



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: