

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST GLYCOL TANK

SITE AND BLDG #: WV046-02

MECHANIC


SIGNATURE: James R Groat JrDATE: 09/30/2025

LOCATION/RM #:

WO# 19973ASSET # 9336

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO			
SPECIAL INSTRUCTIONS						
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X				
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Examine exterior of tank, including fittings, gauges, structural supports, manholes, and handholes for leaks, signs of corrosion, or other defects.	X				
2	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	X	X	controls were not manipulated at this time		
3	Check condition of agitators and/or float assemblies.	X				
4	If applicable, clean strainer(s).					
5	Clean up work site.- Report any issues	X				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: