

Argent Inspections

Form AI-03

Boiler Inspection Report

Inspection Date 8/4/2023	Certificate Issued No	Expiration Date	Prepared for Inspection Yes	Next Watersides/Firesides 2024/2024	Next Strength Test
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer 99th RSC R4C WV046 USARC Parkersburg			Boiler Location Name and/or Building Number Boiler Room		
Address 4603 Camden Ave.			Boiler Location Address		
City Parkersburg		State WV	Zip 26101-1295	City	State Zip
National Board # 110612	Jurisdiction # Asset#6635	Property # #1	Boiler Use Closed Heating Loop	Fuel Type Natural Gas	
Manufacturer Laars		Model # NTH150NXN2		Serial # G10 110612	Year Built 2010
Capacity 150,000 BTU/HR	Design Pressure 30 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Laars	Burner Manufacturer Laars	
Number of Safety Valves 1	Combustion Efficiency % CO2	ppm CO	% Excess O2	Flue Gas Temperature Degrees F	
	Valve Manufacturer Watts	Size 1"	Set Pressure 30 psi	Capacity 1,005,000 BTU/HR	Lift Pressure Hand
Valve 2:					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Flow Switch, Operating Temperature Control, Remote Emergency Disconnect, and the safety valve was lifted by hand per NBIC Part 2 para. 2.5.7(e). It lifted freely and reseated with no leakage.					
Reason(s) for Declining Certification Flow switch did not shut boiler down when water flow stopped.					
Comments This boiler was inspected per UFC 3-430-07, The BTU input of this boiler is below the minimum for which UFC 3-430-07 requires mandatory inspections. In the interest of safety, the boiler was inspected at the request of the activity as allowed by Para. 1-5 of UFC 3-430-07. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. Light debris observed on firesides. Flow switch did not shut boiler down when water flow stopped. Repair or replace the flow switch. All other safety devices tested functioned properly during the inspection process. Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments No	Technical Manager Jerry Kuykendall	Signature 			

Argent Inspections

Form AI-03

Boiler Inspection Report

Inspection Date 8/4/2023	Certificate Issued Yes	Expiration Date 8/4/2024	Prepared for Inspection Yes	Next Watersides/Firesides 2024/2024	Next Strength Test
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer 99th RSC R4C WV046 USARC Parkersburg			Boiler Location Name and/or Building Number Boiler Room		
Address 4603 Camden Ave.			Boiler Location Address		
City Parkersburg		State WV	Zip 26101-1295	City	State Zip
National Board # CI-WV001	Jurisdiction # Asset#6578	Property # #1	Boiler Use Closed Heating Loop	Fuel Type Natural Gas	
Manufacturer H B Smith		Model # G210-SB7		Serial # H9000045	Year Built
Capacity 225,000 BTU/HR	Design Pressure 30 psi	Operating Pressure 12-20 psi	Programmer Manufacturer H B Smith	Burner Manufacturer H B Smith	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2				Flue Gas Temperature Degrees F
	Valve Manufacturer Apollo	Size 3/4"	Set Pressure 30 psi	Capacity 535,000 BTU/HR	Lift Pressure Hand
Valve 2:					Sat
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Low Water Cutoff, Operating Temperature Control, High Temperature Lockout, Remote Emergency Disconnect, and the safety valve was lifted by hand per NBIC Part 2 para. 2.5.7(e). It lifted freely and reseated with no leakage.					
Reason(s) for Declining Certification					
Comments This boiler was inspected per UFC 3-430-07, and ASME Section IV. The BTU input of this boiler is below the minimum for which UFC 3-430-07 requires mandatory inspections. In the interest of safety, the boiler was inspected at the request of the activity as allowed by Para. 1-5 of UFC 3-430-07. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. Light debris observed on firesides. Unable to perform watersides inspection, could not drain boiler. All safety devices tested functioned properly during the inspection process. Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments	Technical Manager	Signature 			
No Pages	Jerry Kuykendall				

Argent Inspections

Form AI-03

Boiler Inspection Report

Inspection Date 8/4/2023	Certificate Issued No	Expiration Date	Prepared for Inspection Yes	Next Watersides/Firesides 2025/2024	Next Strength Test
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer 99th RSC R4C WV046 USARC Parkersburg			Boiler Location Name and/or Building Number Boiler Room		
Address 4603 Camden Ave.			Boiler Location Address		
City Parkersburg		State WV	Zip 26101-1295	City	State Zip
National Board # 389874	Jurisdiction # Asset#6538	Property # #1	Boiler Use Closed Heating Loop	Fuel Type Natural Gas	
Manufacturer Apex		Model # APX525C		Serial # 65588268	Year Built 2017
Capacity 500,000 BTU/HR		Design Pressure 160 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Alex	Burner Manufacturer Apex
Number of Safety Valves 1		Combustion Efficiency % CO2 ppm CO % Excess O2			Flue Gas Temperature Degrees F
	Valve Manufacturer Watts	Size 1"	Set Pressure 50 psi	Capacity 797,000 BTU/HR	Lift Pressure Hand
Valve 1					Reseat Pressure Sat
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Blocked Flue Switch, Blocked intake Switch, Combustion Air by Blower Speed, Flow Switch, Low Water Lockout, Operating Temperature Control, Remote Emergency Disconnect, and the safety valve was lifted by hand per NBIC Part 2 para. 2.5.7(e). It lifted freely and reseated with no leakage.					
Reason(s) for Declining Certification Low and high gas pressure switches not connected ASME-CSD-1 Table CF-162-1. High temperature limit could not be tested, technician did not have code for controller. UFC 03-430-07 Chapter 7 requires testing of safety devices.					
Comments This Hot Water Heating Boiler was inspected per UFC 3-430-07, ASME CSD-1, and the National Board Inspection Code. Light debris observed on firesides. This is a direct fired boiler and ASME-CSD-1 Table CF-162-1 requires these Low and high gas pressure switches be connected to shutdown and lockout the boiler. High temperature limit could not be tested, technician did not have code for controller. UFC 03-430-07 Chapter 7-1 requires testing of safety devices. All other safety devices tested functioned properly during the inspection process. Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments Yes 2 Pages	Technical Manager Jerry Kuykendall	Signature 			

Argent Inspections

Form AI-03

Boiler Inspection Report

Inspection Date 8/4/2023	Certificate Issued No	Expiration Date	Prepared for Inspection Yes	Next Watersides/Firesides 2025/2024	Next Strength Test
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer 99th RSC R4C WV046 USARC Parkersburg			Boiler Location Name and/or Building Number Boiler Room		
Address 4603 Camden Ave.			Boiler Location Address		
City Parkersburg		State WV	Zip 26101-1295	City	
National Board # 160929	Jurisdiction # Asset#6641	Property # #2	Boiler Use Closed Heating Loop	Fuel Type Natural Gas	
Manufacturer Laars		Model # NTH500NZN2		Serial # G10 160929	Year Built 2010
Capacity 500,000 BTU/HR	Design Pressure 160 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Laars	Burner Manufacturer Laars	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2				Flue Gas Temperature Degrees F
Valve 1	Valve Manufacturer Apollo	Size 3/4"	Set Pressure 75 psi	Capacity 972,000 BTU/HR	Lift Pressure Hand
Valve 2					Sat
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Blocked intake Switch, Combustion Air by Blower Speed, Flow Switch, Low Water Lockout, Low Gas Pressure Switch, High Gas Pressure Switch, Operating Temperature Control, Remote Emergency Disconnect, and the safety valve was lifted by hand per NBIC Part 2 para. 2.5.7(e). It lifted freely and reseated with no leakage.					
Reason(s) for Declining Certification No high temperature limit installed as required by ASME CSD-1 Part CW-410 ©. No manual main gas shut off valve installed as required by ASME CSD-1 Part CF-150 ©.					
Comments This Hot Water Heating Boiler was inspected per UFC 3-430-07, ASME CSD-1, and the National Board Inspection Code. Light debris observed on firesides. No high temperature limit installed as required by ASME CSD-1 Part CW-410 (c). All other safety devices tested functioned properly during the inspection process. Discharge of safety valve should be piped back to Glycol supply tank. No manual main gas shut off valve installed as required by ASME CSD-1 Part CF-150 ©. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments Yes 2 Pages	Technical Manager Jerry Kuykendall	Signature 			

Argent Inspections

Form AI-04

Pressure Vessel Inspection Report

Inspection Date 8/4/2023	Certificate Issued No	Expiration Date	Prepared for Inspection Yes	Inspection Type: <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> External <input checked="" type="checkbox"/> Operational <input checked="" type="checkbox"/> Pressure
Customer 99 RSC R4C WV046 USARC Parkersburg			UPV Location Name and/or Building Number Boiler Room	
Address 4603 Camden Ave.			UPV Location Address	
City Psrkersburg		State WV	Zip 26101-1295	City
National Board # 2237418	Property #	Manufacturer Manchester		Serial Number NB 2237418
Pressure Vessel Type <input checked="" type="checkbox"/> Air Receiver <input type="checkbox"/> Autoclave <input type="checkbox"/> Heat Exchanger <input type="checkbox"/> Hot Water <input type="checkbox"/> Nitrogen <input type="checkbox"/> Oxygen <input type="checkbox"/> Other				
Capacity 16 cu. ft.	Design Pressure 200 psi	Operating Pressure 150 psi	Test Pressure 150 psi	Number of Safety Valves 1
	Valve Manufacturer Valve 1: Kingston	Size 1/4"	Capacity (CFM) 200 psi	Setting (PSI)
	Valve 2			Valve Condition Sat.
Reason(s) for Declining Certification Install 2 foundation bolts as required by NBIC Section 1.6.1.				
Comments This air receiver was inspected per UFC 3-430-07 and the National Board Inspection Code. Vessel was inspected externally. All paint and welds are in good condition. Vessel was measured ultrasonically. All readings were satisfactory as compared to shell design thickness. The safety relief valve was removed and tested using an inert gas (nitrogen) and a regulator. Install 2 foundation bolts as required by NBIC Section 1.6.1.				
Inspector Commission 13373	Inspector Dale Brooks	Signature 		
Attachments Yes 2 Pages	Jerry Kuykendall	Signature 		