

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TANKS, WATER STORAGE

SITE AND BLDG #: WV 053 -03

LOCATION/RM #: BLDG #3 WO# 10801 ASSET # 501

MECHANIC
SIGNATURE:

DATE:

9/20/11

START TIME:

FINISH TIME:

CHECK ITEM#	CHECKPOINT DESCRIPTION	TASKS COMPLETED		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		✓	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank including fittings, manholes, and handholes for leaks, signs of corrosion, and correct as indicated.	✓		
2	Inspect structural supports and repair or replace damaged insulation or covering. If insulation contains asbestos and is damaged or eroded, it is considered a hazardous waste.	✓		
3	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	✓		
4	Clean up work site.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: