

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: **WV 053 - 2**LOCATION/RM #: **bridge bays** WO# **10836** ASSET # **8023**MECHANIC
SIGNATUREDATE: **8/25/19**

START TIME:

8:30FINISH TIME: **8:50**

ITEM NUMBER	DESCRIPTION	CLASS CONDITION	NOTES/ACTIONS	
			YES	NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
	TO BE PERFORMED EACH INSPECTION SERVICE			
1	Start and stop fan with local switch			
2	Check motor and fan shaft bearings for noise, vibration, overheating, lubricate bearings			
3	Inspect, adjust belts and pulleys. Replace belt as needed.			
4	Clean dampers, lubricate pivot points (annually) and inspect linkages for tightness.			
5	Inspect fan for bent blades, unbalance, excessive noise and vibration			
6	Clean fan as needed.			
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.			
8	Repair as needed			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

11 *Pc*