

Tidewater, INC
VA-011
1821 Industry St.
Culpeper VA 22701
(410) 540-8700

Recorded By: **Marshall Kohne**
(301) 721-2663
mkohne@bondwater.com

Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	2629 5000 max			
pH	9.4 8 - 10.5			
Molybdate (ppm as Mo)	100 50 - 200			

Closed LoopOnline 

All readings indicate good levels of protection for closed system. Readings recorded after adding a half pound of powdered MO used for a volume test. The boiler has been repaired and I am waiting on my vendor for glycol pricing.