

CMI Management
 VA 002
 6901 Telegraph Rd
 Alexandria VA 22310
 (202) 437-5119

Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

Boiler Room - HVAC Equipment

Test	Dual Temp Loop			
Conductivity (as mmhos)	5518 3500 max			
Molybdate (ppm as Mo)	0 65 - 150			
pH	8.4 8 - 10.5			

Opening Comment

Performed Quarterly Service Visit

Site visit was performed by technician Marshall Kohne

Dual Temperature Closed Loop

Online 

Readings indicate high conductivity and low inhibitor residual. Attempted to add corrosion inhibitor to 1 gallon bypass feeder but the feeder is not functional anymore. Will return soon in coordination with on site personnel to hand pump in BOND 5011 for additional corrosion protection.

Will continue to monitor conductivity closely.