

Tidewater, INC
VA-011
1821 Industry St.
Culpeper VA 22701
(410) 540-8700

Recorded By: **Marshall Kohne**
(301) 721-2663
mkohne@bondwater.com

Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	575 5000 max			
pH	8.1 8 - 10.5			
Molybdate (ppm as Mo)	0 50 - 200			

Evaporative CondenserOnline 

System was idle. System is still being piped to cooling tower controller. System is currently chemically untreated.

Closed LoopOnline 

Molybdenum level is low. This will lead to accelerated corrosion rates. MO and Glycol are both low due to system being down for repairs. Chris informed me that the system should be fixed by the first of the year. The system is in jeopardy of possible pipe breakage as well if we get cold weather before the system is chemically treated.