

CMI Management  
 VA 002  
 6901 Telegraph Rd  
 Alexandria VA 22310  
 (202) 437-5119

Recorded By: Marshall Kohne  
 (301) 721-2663  
 mkohne@bondwater.com

### Boiler Room - HVAC Equipment

Test	Dual Temp Loop			
Conductivity (as mmhos)	3520 3500 max			
Molybdate (ppm as Mo)	0 50 - 200			
pH	7.4 8 - 10.5			

#### Dual Temperature Closed Loop

Online 

Molybdenum level is low. This will lead to accelerated corrosion rates. I added 1 gallon of MO/5011 to the systems pot feeder and retested before leaving, all readings are now in desired ranges. I also changed the systems filter.