

Tidewater, INC
 VA-049
 6700 Strathmore Rd.
 North Chesterfield VA 23237
 (410) 540-8700

Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

Boiler Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	1747 4000 max	1153 4000 max		
pH	9.3 8 - 10.5	10.4 8 - 10.5		
Molybdate (ppm as Mo)	200 50 min	200 50 min		

Opening Comment

Performed scheduled service visit.

Hot Water Loop

Online 

All readings indicate good levels of protection for closed system. Corrosion inhibitor residual is excellent at this time.

Chill Water Loop

Offline 

All readings indicate good levels of protection for closed system. Corrosion inhibitor residual is excellent at this time. Chill Loop is Offline