

CMI Management
 VA-011
 1821 Industry St.
 Culpeper VA 22701
 (202) 437-5119

Recorded By: Marshall Kohne
 (301) 721-2663
 mkohne@bondwater.com

Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	1055 3500 max			
pH	8.3 8 - 10.5			
Molybdate (ppm as Mo)	50 50 - 200			

Closed Loop

Online

All readings indicate good levels of protection for closed system. Bond has successfully completed the draining of the system and added new glycol to the loop.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.