

Tidewater, INC
VA-011
1821 Industry St.
Culpeper VA 22701
(410) 540-8700

Recorded By: **Marshall Kohne**
(301) 721-2663
mkohne@bondwater.com

Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	2486 5000 max			
pH	9.2 8 - 10.5			
Molybdate (ppm as Mo)	50 50 - 200			

Closed LoopOnline 

All readings indicate good levels of protection for closed system. The draining of the system has been complete as well as installation of new glycol. I collected a sample which will be sent to the lab for testing. Jon will contact management with results once received.