

Tidewater, INC  
 VA-011  
 1821 Industry St.  
 Culpeper VA 22701  
 (410) 540-8700

Recorded By: Marshall Kohne  
 (301) 721-2663  
 mkohne@bondwater.com

#### Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	2493 5000 max			
pH	9.2 8 - 10.5			
Molybdate (ppm as Mo)	50 50 - 200			

#### Evaporative Condenser

Online 

System was idle. System is still being piped to cooling tower controller. System is currently chemically untreated.

#### Closed Loop

Online 

All readings indicate good levels of protection for closed system. The glycol delivery was being made today as well. We will soon flush the loop and add the new glycol to the system.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its Insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.