

CMI Management
 MD 021
 1850 Baltimore Rd
 Rockville MD 20851-1298
 (202) 437-5119

Report Number: 458001

Recorded By: James Harris
 (410) 991-7190
 jharris@bondwater.com

1850 Baltimore Rd - HVAC

Test	Closed loop			
Conductivity (as mmhos)	2800 Record			
pH	8.4 8.5 - 10.5			
Molybdate (ppm as Mo)	125 65 - 150			

Opening Comment

Performed quarterly water treatment service.

Closed loop

Online 

Testing found all levels within desired ranges indicating good corrosion protection by the chemical treatment at this time. The filter on the closed loop was replaced during this visit.

Closing Comment

Please contact me with any questions concerning the treatment program.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customers wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.