

CMI Management
 VA 002
 6901 Telegraph Rd
 Alexandria VA 22310
 (202) 437-5119

Recorded By: Marshall Kohne
 (301) 721-2663
 mkohne@bondwater.com

Boiler Room - HVAC Equipment

Test	Dual Temp Loop			
Conductivity (as mmhos)	2344 3500 max			
Molybdate (ppm as Mo)	70 65 - 150			
pH	8.4 8 - 10.5			

Dual Temperature Closed Loop

Online 

All readings indicate good levels of protection for closed system. I also collected a sample of water to be sent to our lab to check the quality of glycol in the system. John Miller will be in touch with the results once received.