

# PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST SLIDE GATE OPERATOR & ENTRY SYSTEM (AUTOMATED ACCESS SYSTEM)

SITE AND BLDG #: 109050

MECHANIC SIGNATURE: [Signature]

DATE: 8/14/15

LOCATION/RM #: WO# 4737 ASSET # 10025

START TIME:

FINISH TIME:

ITEM NO.	CHECKPOINT DESCRIPTION	SCHEDULED INSPECTIONS	TASK COMPLETE		NOTES/ACTIONS
			YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		<input checked="" type="checkbox"/>		
2	Schedule shutdown with operating personnel.		<input checked="" type="checkbox"/>		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		<input checked="" type="checkbox"/>		
4	This work should be scheduled at non-peak hours.		<input checked="" type="checkbox"/>		
5	Notify affected personnel before performing PM (alarmed or security entrances).		<input checked="" type="checkbox"/>		
TOTAL DEFICIENCIES: 0					
1	Check gate for proper operation, binding, or misalignment; adjust as necessary.		<input checked="" type="checkbox"/>		
2	Check gate wheels, rollers and guides for wear; replace as necessary.		<input checked="" type="checkbox"/>		LUBRICATE WHEELS
3	Inspect drive belt for alignment, tightness and wear.		<input checked="" type="checkbox"/>		
4	Check chain for sagging, tighten if necessary.		<input checked="" type="checkbox"/>		4 CLEAR DRIVE ROLLERS
5	Check that the gate reverses on contact with an object in both the opening and closing cycles. Adjust the clutch if necessary.		<input checked="" type="checkbox"/>		ADJ CLUTCH
6	Check vehicular reverse and shadow loops for proper operation.		<input checked="" type="checkbox"/>		
7	Check manual release for proper operation.		<input checked="" type="checkbox"/>		
8	Check keyless entry pad and intercom system/call box for proper operation (entry pad outside of facility)		<input checked="" type="checkbox"/>		
9	Check keyless entry UPS battery. Replace if needed		<input checked="" type="checkbox"/>		
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.		<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any efficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

ASSISTANT - 11.00 - 4977 - DO NOT WORK ANYWHERE OF IT  
Page 1 of 1