

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY GENERATORS

SITE AND BLDG #:

K-24050
LOCATION/RM #: ROOK WO# 4766 ASSET # 9972

MECHANIC
SIGNATURE M. Manasee

DATE: 8/13/2015

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO PROVIDED EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>		
2	Review and follow manufacturer's instructions. One copy of the instruction manual(s) shall be kept in a secure, convenient location near the equipment and another kept in a different location.	<input checked="" type="checkbox"/>		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
4	A written record of all inspections, service, tests, operation, and repairs to the emergency generator shall be maintained in an equipment log book and kept on the premises. This record shall include the date of maintenance, identity of service personnel, and notation of any unsatisfactory condition and the corrective action taken, including parts replaced.	<input checked="" type="checkbox"/>		<i>CLEAR GENERATOR EQUIPMENT.</i>
5	Have a properly serviced fire extinguisher in proper working order on hand.	<input checked="" type="checkbox"/>		
6	Follow NFPA 110 and 111 for operation and maintenance requirements.	<input checked="" type="checkbox"/>		
TOP PERFORMANCE AT EACH INSPECTION SERVICE				
1	Fuel check main and day tank fuel supply levels; day tank float switch; piping, hoses and connectors; operating fuel pressure; and for any obstructions to tank vents and overflow piping.	<input checked="" type="checkbox"/>		
2	Oil (check for proper oil level and oil operating pressure; lube oil heater) <ul style="list-style-type: none"> • Engine oil level should be checked with the unit stopped • Check unit for recommended proper oil pressure 	<input checked="" type="checkbox"/>		
3	Cooling system (check coolant level, water pump(s), jacket water heater, belts, hoses, fan)	<input checked="" type="checkbox"/>		