

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
SUMP PUMP

SITE AND BLDG #: NY001

LOCATION/RM #: WO# 1437 **ASSET #** 9068

**MECHANIC
SIGNATURE:**

Dave Rappel

DATE: 12-13-18

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
STANDARD INSPECTION ITEMS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X		
2	Schedule outage with operating personnel.	X		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
4	If the material removed from the pump is hazardous, contact the Regional S&EM office for disposal instructions.		X	N/A
5	If strainer cleaning requires removal of pump unit which should be considered a repair and not general maintenance.		X	N/A
6	Excessive sediment and debris, not removed by flushing the pit should be handled on a project basis, and not considered under this standard.	X		
TO BE PERFORMED DAILY DURING INSPECTION SERVICE				
1	Remove cover plates and flush pit.	X		
2	Inspect check valve.	X		
3	Inspect interior of pit for cracks.	X		
4	Inspect cover plate gaskets and replace if necessary.	X		
5	Insure the unit is operating properly, report any deficiencies	X		
6	Clean up work area and remove all debris.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: