

# PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST KITCHEN HOOD

ACTIVITY AND BLDG #: NY001

MECHANIC  
SIGNATURE: Dave Ruppel

DATE: 12-13-18

LOCATION/RM #: \_\_\_\_\_ WO# 1566 ASSET # 9069

START TIME: \_\_\_\_\_

FINISH TIME: \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean all accessible surfaces thoroughly.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Check all louvers and dampers. If dampers must be moved to ensure complete cleaning, ensure they will be marked and returned to their original position to prevent unbalancing the system.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Clean and/or replace filters, if applicable.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Ensure unit is operating properly, not any deficiencies.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<u>Unit is disabled - abandoned building 4 sale</u>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: