

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST UNIT HEATER, HOT WATER

SITE AND BLDG #:

64024-358

MECHANIC
SIGNATURE:

LOCATION/RM #:

WO# 1633 ASSET # 9773

DATE: 12/24/19

START TIME: 11:50 AM

FINISH TIME: 2:00 PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒	☐	
2	Schedule shutdown with operating personnel.	☒	☐	
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒	☐	
JOB PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.	☒	☐	
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	☒	☐	OK
3	Clean the coil with vacuum cleaner.	☒	☐	Clean
4	Comb the fins as needed.	☒	☐	OK
5	Clean all fans and motors.	☒	☐	OK
6	Check operation of controls and safeties.	☒	☐	OK
7	Lubricate as required.	☒	☐	Yes
8	Check all motors, belts, pulleys, shafts, etc. for alignment.	☒	☐	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Worker

Additional Notes: