

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: NY024-208

LOCATION/RM #: 3/4 WO# 6153

MECHANIC SIGNATURE: P. Dubanev

DATE: 12/5/15

START TIME: _____ FINISH TIME: _____

1	Check, clean, and/or replace filters as required.		
2	Initial and Date Filter (if disposable)		
3	Initial and Date Yellow Maintenance Tag (if applicable)		
ASSET #	ST-2K	6153	
9606	FILTER- 20X22X2	4	REPLACE
	20X25X2	2	REPLACE
			CLEAR AIR HANDLER UNIT
			OK
	BELT 4C380	1	OK
			LUBRICATE MOTOR & BEARING
			REPLACE
ASSET #	FILTER- 16X25X2	2	REPLACE
9607	BELT- 4C380	1	OK
			CLEAR AIR HANDLER UNIT
			OK
			LUBRICATE MOTOR & BEARINGS

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Technician
Additional Notes: