

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: 14024-208 MECHANIC SIGNATURE: P. Dubanew DATE: 12/5/19

LOCATION/RM #: 300 WO# 6154 START TIME: 6:55 FINISH TIME:

		yes	no
1	Check, clean, and/or replace filters as required.	☒	☐
2	Initial and Date Filter (if disposable)	☒	☐
3	Initial and Date Yellow Maintenance Tag (if applicable)	☒	☐
ASSET #	<u>5124</u>	☒	☐
9607	<u>FILTER - 20X20X2</u>	☒	☐
	<u>20X25X2</u>	☒	☐
	<u>BELT 1346</u>	☒	☐
9608	<u>FILTER - 16X25X2</u>	☒	☐
	<u>BELT 41360</u>	☒	☐
	<u>CLEAN AIR HANDLER UNIT</u>	☒	☐
	<u>& COIL</u>	☒	☐
	<u>LUBRICATE MOTOR & BEARINGS</u>	☒	☐
		☒	☐
		☒	☐
		☒	☐
		☒	☐
		☒	☐

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Technician
Additional Notes: