

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST FILTER REPLACEMENT

SITE AND BLDG #:	LOCATION/RM #:
WY 024-228	200 WO# 6160
6158	

MECHANIC SIGNATURE: *D. DeBrosse* DATE:

START TIME: FINISH TIME:

LOCATION/RM #:	WO#	DATE	TIME	INITIALS	DESCRIPTION	REMARKS
1					Check, clean, and/or replace filters as required.	
2					Initial and Date Filter (if disposable)	
3					Initial and Date Yellow Maintenance Tag (if applicable)	
ASS-CT 4	5/12/14					
9611	FIGER- 20X22X2					REPLACE
	20X25X2					REPLACE
						LUBRICATE MOTOR & BEARINGS
						CLEAN AIR HOODER UNIT
						OK
	BELT - BX42					OK
						REPLACE
ASS-CT 4	FIGER- 16X25X2					OK
9613	13 EGT- 46 360					CLEAN AIR HOODER UNIT
						LUBRICATE COIL
						CUBRICATOR MOTOR & BEARINGS

Additional Notes:
To be performed by: General Maintenance Technician
Note: The technician shall perform any repairs identified during PM up to \$250 (under labor and direct materials) exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.