

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: RY024-208 MECHANIC SIGNATURE: D. Dubuc DATE: 12/9/15
LOCATION/RM #: MECAWO# 6167 START TIME: FINISH TIME:

1	Check, clean, and/or replace filters as required.	YES	NO
2	Initial and Date Filter (if disposable)		
3	Initial and Date Yellow Maintenance Tag (if applicable)		
ASSET #	SIZE		
9619	FILTER - 20X25X2	4	1
			REPLACE CLEAN AIR HANDLER W/IT & COIL REPLACE MOTOR & BEARING OK
	BELT - AX43	1	
ASSET #	FILTER - 16X25X2	2	
9620	BELT - A37	1	
			REPLACE MOTOR & BEARING CLEAN AIR HANDLER W/IT & COIL

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician
Additional Notes: