

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: 24024-356 MECHANIC SIGNATURE: Dickinson DATE: 12/3/19

LOCATION/RM #: MECH ROOM WO# 6173 START TIME: _____ FINISH TIME: _____

1	Check, clean, and/or replace filters as required.		
2	Initial and Date Filter (if disposable)		
3	Initial and Date Yellow Maintenance Tag (if applicable)		
ASSET #	SIZE		
9705	FILTER - 20X20X2	6/1	REPLACED
	FIRAC - 16X20X4	6	REPLACED
	BELT - AX53	1	OK
			CLEAN AIR HANDLER UNIT
			VACUUM COIL
			LUBRICATE MOTOR & BEARINGS

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: