

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #: NY 024- 356

MECHANIC SIGNATURE: Pullarier-

DATE: 12/6/13

LOCATION/RM #: WO# 6205 ASSET # 9759

START TIME:

FINISH TIME:

1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	ASSET # 9759
2	Schedule and coordinate work with operating personnel.	✓	(2) LIGHT BOB OUT
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	They aware of it.
1	Open and tug switch.	✓	
2	Inspect visual condition of wiring. Look for evidence of overheating.	✓	yes
3	Check for proper light operation.	✓	yes
4	Test operation of automatic switches/ time clock/ photocells if applicable.	✓	yes
5	Inspect light pole and mounting devices for deficiencies.	✓	CHANGE TO EMER
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

ASSET # - W.O.H
PM-NO-9759 - 6205-4 PC DOUBLE LIGHT POLE
PM-SA-9759 - 6358-4 PC DOUBLE LIGHT POLE