

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST FILTER REPLACEMENT

SITE AND BLDG #: 27050

MECHANIC SIGNATURE: *[Signature]* DATE: 12/9/95

START TIME: FINISH TIME:

LOCATION/UNIT #	DATE	TIME	STATUS	REMARKS
1	✓			Check, clean, and/or replace filters as required.
2	✓			Initial and Date Filter (if disposable)
3	✓			Initial and Date Yellow Maintenance Tag (if applicable)
455-074	✓	8:20	41	REPLACE
9952	✓	8:22		BEELT - A52
	✓		1	OK
	✓			CLEAN MOTORS & LUBRICATE UNIT

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found

To be performed by: General Maintenance Technician

Additional Notes: