

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST GREASE TRAP

SITE AND BLDG #: 124050

MECHANIC
SIGNATURE: William

DATE: 12/10/15

LOCATION/RM #: WO# 6212

ASSET # 10023

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
3	Insure proper grease disposal.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Do not use enzymes, acids, caustics, solvents or emulsifying products when cleaning or maintaining the grease traps.	☒		GREASE TRAP
2	Remove lid. If the trap is equipped with removable baffles, remove them.	☒		WORKING FINE
3	Make sure the flow restrictor on the inflow pipe is present.	☒		
4	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.	☒		CLEAN GREASE TRAP
5	Replace lid and baffles.	☒		HOUSING
6	Return (or fill) water to grease trap.	☒		
7	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years.	☒		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: