

PM-F&R-10423

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

AIR HANDLER

MECHANIC
SIGNATURE

Dave Conrad

DATE: 12/18/2018

		Pre-Service Inspection					
		Initial		Annual			
Task	Description	Initial	Annual	Initial	Annual	Initial	Annual
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X					
2	Remove power at Drive or at Breaker Panel. Verify with tester or meter that power has been removed. Install lock out tag out if servicing alone or in confined space for safety precautions.	X					
3	Check fan blades and moving parts for cracks and excessive wear.	X					
4	Check running motor amperages on all three phases (record in note column) notate L1, L2, and L3 amp draws.		X	1.1	1.2	1.3	<i>Two N/A</i>
5	Tighten all electrical connectors/lugs to proper torque.	X					<i>All tight and secured</i>
6	If unit is a multi-zone air handler, then check each individual zone damper and associated controls.		X				<i>N/A</i>
7	Check bearing collar set screws on fan shaft to make sure they are tight.		X				
8	Check filters for dirt accumulations, replace as necessary. Check belt, repair or replace as necessary.		X				
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.		X				
10	Check coils for leaking, tightness of fittings.		X				
11	Use fin comb to straighten coil fins.		X				<i>All good and straight</i>
12	If applicable, clean strainer (annually).		X				<i>N/A</i>
13	Flush and clean condensate pans and drains, remove all rust, prepare metal and paint. Hose down coils and drain pans and wash with an appropriate EPA approved solution approved solution. Treat condensate pans with an EPA approved biocide.	X					<i>All Clean</i>

Polder 2002 NY060 Dec 2018 PM Air Handler # 10423

14	Check belts for wear and cracks, adjust tension or alignment. Replace belts when necessary. Multi-belt drives shall only be replaced with matched sets.	X	
15	Check rigid couplings for alignment on direct drives, and for tightness of assembly. Check flexible couplings for alignment and wear.	X	
16	Check and test freezestat for proper operation	X	X INR0 N/A
17	Vacuum interior of unit.	X	
18	Check filter doors and access doors for proper gasketing and air leaks. Correct as necessary.	X	
19	Lubricate fan shaft bearings while unit is running. Add grease slowly until slight bleeding is noted from the seals. Do not over lubricate. Remove old or excess lubricant.	X	
20	Clean up work area.	X	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: