

PM-SA-10432

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: NY060 Reserve Bldg
LOCATION/RM #: 138 WO# 1513 ASSET # 10432

MECHANIC
SIGNATURE:

David Rappel DATE: 12/18/2018

START TIME:

FINISH TIME:

1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		
1	For gsa/oil heaters: 1. Remove access panels if applicable. 2. Check the fire box liner or refractory for cracks and leaks. 3. Check all gas lines for leaks. Repair as needed.		
2	Clean dirt from heater. Vacuuming is preferred.	X	
3	Check operation of gas valve.	X	
4	Check for gas leaks.	X	
5	Check operation of thermostat.		
6	If applicable, replace primary air intake filter.		
7	As needed, clean spark electrode and reset gap, replace if necessary.		
8	Inspect flue pipe and connections.	X	
9	If applicable, inspect and clean outside air blower and blower intake.		
10	Inspect unit for proper operation.	X	
11	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Factory Technician Has Just Completed Work/Maintenance on this unit.
Everything is 100%
cow