

PM-SA-10513

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
UNIT HEATER, ELECTRICSITE AND BLDG #: NY060 OWS  
LOCATION/RM #: 1112 WO# 1518 ASSET # 10513MECHANIC  
SIGNATURE:

David Rappel DATE: 12/18/2018

START TIME:

FINISH TIME:

| 1 | In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.   | X |  |
|---|--|---|--|
| 2 | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.  | X |  |
| 1 | Check heater coils and associated piping for leaks or corrosion.   | X |  |
| 2 | Clean heating coil. Brush vacuum where accessible.   | X |  |
| 3 | Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections. | X |  |
| 4 | Inspect fan for bent blades, unbalance, excessive noise and vibration.   | X |  |
| 5 | Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.  | X |  |
| 6 | Verify proper control by modulating the thermostat through complete cycle.   | X |  |
| 7 | Inspect unit for proper operation.   | X |  |
| 8 | Inspect unit for overall condition and recommend for replacement or other needed repairs.  | X |  |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: