

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GATES, FENCES, SECURITY AND ACCESS

SITE AND BLDG#: WY116-02

LOCATION/RM#: WO# **ASSET#**

MECHANIC SIGNATURE: John L. Lewis **DATE:** 1/17/20

START TIME: **FINISH TIME:**

CHECK POINT	CHECK POINT DESCRIPTION	TASK COMPLETED		NOTES/ACTIONS
		DATE	NO.	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
ROUTINE MAINTENANCE INSPECTION STANDARDS				
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	<input checked="" type="checkbox"/>		LUBRICATE PIVOTS
2	Check all locking devices. Lubricate as required.	<input checked="" type="checkbox"/>		LOCKING DEVICES
3	Inspect center gate support rollers and lubricate as required.	<input checked="" type="checkbox"/>		
4	Clean roller track of any debris.	<input checked="" type="checkbox"/>		CLEAN ROLLER TRACK
5	Check bolts, fasteners, and mounting hardware. Tighten or adjust as necessary.	<input checked="" type="checkbox"/>		
6	Check for any obstructions that retard full swing or movement of the gate.	<input checked="" type="checkbox"/>		
7	Check that shrubs and trees are pruned clear of gate.	<input checked="" type="checkbox"/>		
8	Check hold open devices for proper operation. Lubricate as required.	<input checked="" type="checkbox"/>		

ASSET# - WY116

WY116-10772-6325
WY116-10773-6326
WY116-10774-6321
WY116-10775-6322
WY116-10776-6323
WY116-10777-6324