

PM-QT-9016

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
ICE MAKER

SITE AND BLDG #:

NY001

LOCATION/RM #:

WO# 2322 ASSET # 9016

MECHANIC
SIGNATURE:

Dave Rypel

DATE: 2-4-2019

START TIME:

FINISH TIME:

1	Review manufacturer's instructions.		
2	De-energize, lock out, and tag electrical circuits.		
3	If appliance is disposed, follow regulations concerning removal of refrigerants and disposal of the appliance.		
4	If materials containing refrigerants are discarded, comply with EPA regulations as applicable.		
5	Only approved cleaning chemicals shall be used.		
1	Check with operating or area personnel for any deficiencies; verify cleaning program.		
2	Visually check for refrigerant, oil and water leaks.		
3	Inspect ice condition/size.		
4	As needed, drain and clean unit with proper ice machine cleaning solution.		
5	Check date on water filter. Replace as needed. Water filters should be changed annually at a minimum.		
6	Check and tighten any loose screw-type electrical connections.		
7	Check all controls; adjust if necessary.		
8	Examine water connection; open and close water valve; test ice dispensing valve and (door) metering adjustment.		
9	Check and clear ice machine draining system (drain vent, strainer, trap).		
10	Examine condition of bin doors-closure, hinges, gaskets, handles and ease of slide; lubricate as required. Check storage bin condition.		
11	Clean motor, compressor, and condenser coil.		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

This Asset # 9016 / WO # 2322 (2nd ICE MACHINE) is NOT HERE !!