

EX-1 LIGHTS

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TIME CLOCK, LIGHTING

SITE AND BLDG #: WY024-358

MECHANIC SIGNATURE: P. M. Vause

DATE: 2/19/2019

LOCATION/RM #: _____ **WO#** _____ **ASSET #** _____

START TIME: _____ **FINISH TIME:** _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS <small>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</small>
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Check physical connections.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Verify the timeclock configuration, ensure proper operation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	If applicable, check battery and replace as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

W.O # ASSET #
2407 - PM-01-9809 ✓ ok
2408 - PM-01-9210 ✓ ok