

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

CIRCUIT BREAKER BOOSTER SYSTEM

CIRCULATING AND BOOSTER PUMPS

SITE AND BLDG #: 104024- BDC 208

MECHANIC
SIGNATURE: Ch. Silver DATE: 2/6/2009

LOCATION/RM #: WO# ASSET #

START TIME: _____ FINISH TIME: _____

ITEM NUMBER POINT	CHECKPOINT DESCRIPTION	TASK COMPLETED		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED, NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
3	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.			
TO BE PERFORMED DURING MAINTENANCE SERVICE				
1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication atleast annually.			
2	Inspect couplings and check for any pump seal leaks.			
3	Check motor mounts and vibration pads			ok
4	Tighten all pump flanges.			
5	Visually check pump alignment and coupling			
6	Inspect electrical connections			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

WBB & GNESS - HANNS

~~2478 - Pk - SA - 9683 ✓ ok
2479 - Pk - SA - 9684 ✓ ok
2480 - Pk - SA - 9685 ✓ ok~~