

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #:	<u>UC-050</u>		
LOCATION/RM #:	WO#	ASSET #	MECHANIC SIGNATURE
			<i>Rehman</i>
			DATE: <u>2/14/10</u>
			START TIME:
			FINISH TIME:

1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>	ASSET # <u>10020 - motor</u> POOT SENS. VENT Don't work They cover at. int
2	Schedule and coordinate work with operating personnel.	<input checked="" type="checkbox"/>	
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	
4	Open and tag switch.	<input checked="" type="checkbox"/>	
5	Inspect visual condition of wiring. Look for evidence of overheating.	<input checked="" type="checkbox"/>	
6	Check for proper light operation.	<input checked="" type="checkbox"/>	<i>Yes</i>
7	Test operation of automatic switches/ time clock/ photocells if applicable.	<input checked="" type="checkbox"/>	<i>Yes</i>
8	Inspect light pole and mounting devices for deficiencies.	<input checked="" type="checkbox"/>	
9	For any noted deficiency, takes pictures and open corrective maintenance ticket.	<input checked="" type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

Additional Notes:

ASSET # — W. O #

PM-10019 — 6991 → PC DOWBLE VENT - OK
PM-10020 — 6992 - 4 PC DOWBLE VENT - X