

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: NY054 - 03 **Storage**

MECHANIC
SIGNATURE: Christopher N Pothier **DATE:** 2 - 11 - 20

LOCATION/RM #: Storage **WO#** 7037 **ASSET #** 10142

START TIME:

FINISH TIME:

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|---|--|---------------|----|---|
| | | YES | NO | |
| SPECIAL INSTRUCTIONS | | | | |
| 1 | In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to. | X | | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Inspect for structural defects, note needed repairs | X | | |
| 2 | Push test buttons and observe light operation. Note any units that do not operate properly. | X | | |
| 3 | Clean exterior with dry cloth. | X | | |
| 4 | For Exit lights check for proper arrow direction. | X | | |
| 5 | Make and/or recommend any needed repairs. | X | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: