

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: 109.024-356

WO# 67009 ASSET # 9259

MECHANIC
SIGNATURE: [Signature]

DATE: 1-19-20

LOCATION/RM #:

START TIME:

FINISH TIME:

		1	2	3	4	5	6
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒					
2	Schedule and coordinate work with operating personnel.	☒					
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒					
4	Open and tag switch.	☒					
5	Inspect visual condition of wiring. Look for evidence of overheating.	☒					
6	Check for proper light operation.	☒					
	Test operation of automatic switches/ time clock/ photocells if applicable.	☒					
	Inspect light pole and mounting devices for deficiencies.	☒					
	For any noted deficiency, takes pictures and open corrective maintenance ticket.	☒					

2 lights out BUB
They aware of it.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

done in evening

4 PC DOUBLE LIGHT - 2 BUB OUT