

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #: 119.024-358 MECHANIC SIGNATURE: [Signature] DATE: 1/9/90
LOCATION/RM #: 357 WO#: ASSET # START TIME: FINISH TIME:

1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒			ASSET - 9766-5 BUBB OUT
2	Schedule and coordinate work with operating personnel.	☒			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒			ASSET - 9807 - Don't work They aware of it.
4	Open and tag switch.	☒			
5	Inspect visual condition of wiring. Look for evidence of overheating.	☒			
6	Check for proper light operation.	☒			
7	Test operation of automatic switches/ time clock/ photocells if applicable.	☒			
8	Inspect light pole and mounting devices for deficiencies.	☒			
9	For any noted deficiency, take pictures and open corrective maintenance ticket.	☒			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

CAKE IN EARLY

ASSET # - W.O. #
358-PM-MO-9807-6712 - LIGHT Don't work
357-PM-MO-9766-6711-5 LIGHT BUBB OUT